

ਦਫਤਰ ਸਿਵਲ ਸਰਜਨ, ਅੰਮ੍ਰਿਤਸਰ

PHONE 0183 2211864

nvbdcpamritsar@gmail.com

No.SSI/CS/ASR/2025/15

DATED:- 30/04/2025

Certificate of Cleanliness and Sanitation

This Is To Certify That We Have Inspected The Premises ROYALE CAMBRIDGE SCHOOL WAZIR BHULLAR, BEAS. AMRITSAR ,PUNJAB On Dated 24/04/2025. After Inspecting Their Rooms, Washrooms & Kitchen Cleanliness And Sanitation is found Satisfactory. Facility of portable water with R.O. is also available and All Parameters are Within Acceptable Limits. This certificate is issued on the basis of inspection report submitted by Dr. Harjot Kaur Distt. Epidemiologist. This certificate valid for one year from date of issue.


Civil Surgeon ,Amritsar

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com

To,

Royale Cambridge school
Wazir Bhullar , Beas , Amritsar


No.: DWTLTT/2526/00022 Dated : 17/04/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 29 Dated: 16/04/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 16/04/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : Royale Cambridge school Wazir Bhullar , Beas , Amritsar			Customer Reference No.		No : 29 Dated : 16/04/2025	
			Sample Submitted by		Mr. Paramvir Anad	
			Date of Sample Receipt		16/04/2025	
			Analysis Starting Date		16/04/2025	
			Analysis completion Date		17/04/2025	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC147562500000121F		Sample Type :		Treated Water	
Test Report No.:	DWTLTT/2526/00022		Date of Issue :		17/04/2025	
Registration no.:	DWTLTT/REG2526/00055		Condition of Sample :		Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		NA / NA	
Village :	Wazir Bhular		Habitation :		Wazir Bhular	
Block:	Rayya		District :		Amritsar	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.83@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	48	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.05@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	36	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	28	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	9.62	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.97	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	7.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Tarn Taran

End of the Test Report